

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, November 23, 2020

Corrective Action Required:

1	Misc	- INSULATED WITHOUT APPROVAL REMOVE INSULATION FOR INSPECTION - - PROVIDE 3RD PARTY INSPECTION REPORTS - - DO NOT COVER WORK WITHOUT APPROVAL -
---	------	---

Corrective Action Required:

2	Misc	11/13/2020 Electrical & Mechanical trades not ready for all rough inspection. Documentation regarding third party inspections has not been submitted and is not onsite. Do not cover
---	------	--

Corrective Action Required:

3	Misc	- PROVIDE MEDICAL MC CABLE PATIENT ROOMS & LIGHTS, ALL BRANCH CIRCUITS - - PROVIDE CLEANOUTS WHERE REQUIRED - - BACK TO BACK FITTINGS AT DRAIN BOXES - - PROVIDE SPECIAL INSPECTIONS REPORTS - - DRAIN 2 PIPE SIZE DIMENSIONS FROM TRAP TO WYE - - COVER FACED INSULATION ABOVE CEILING - - PROVIDE BACKING FOR ROOFTOP ACCESS LADDER - - ROOF DRAIN ROOM # 119 - -
---	------	---

Comments: