

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202946  
Address: 2337 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Residential</b>	John Morris	Failed	Tuesday, November 24, 2020

Corrective Action Required:

1	Misc	Complete interior underslab drain tile with positive or neutral slope and connect to sump pit
---	------	---

**Comments:**