

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193184  
Address: 1409 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Tuesday, November 24, 2020

Corrective Action Required:

1	Misc	-Seal all penetrations in siding, seal along top of meter can and AC disconnect -Sump pump discharge minimum 36" from foundation -Remove paint covers from all smokes - basement -GFCI protection required at washing machine receptacle -Access required to jacuzzi tub motor master bath -Cut floor joist above furnace for HVAC duct, header off floor joist
---	------	--

Comments: