

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203773  
Address: 2342 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	John Morris	Failed	Tuesday, November 24, 2020

Corrective Action Required:

1	Misc	-Erosion control requires continuous maintenance. Repair damaged section at rear and establish methods at curb line within 2 businesses days -immediate street cleanup required -establish gravel filter at driveway -provide building address -no further inspections until complete
---	------	---

**Comments:**