

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201933
Address: 1313 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Robb Popp	Failed	Tuesday, November 24, 2020

Corrective Action Required:

1	Miscellaneous Correction	-Install cover plate on receptacles and switches, install pendant lights -Provide AFCI protection per E3902.16
---	--------------------------	---

Comments: