

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20182611  
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Michael Harkins	Failed	Tuesday, November 24, 2020

Corrective Action Required:

1	Miscellaneous Correction	901 ward bldg #4 4th floor Secure windows at all stair landings Handrails in all stairways Fire extinguisher cabinets throughout Elevator equipment room cover plate Remove dust covers smokes corridor 400 ok 402 complete deck rail 404 bad GFCI between stove & refer 405 bath exhaust fan obstruction 406 ok 407 fire caulk ceiling mech room, entry door won't latch 408 fire caulk line set ceiling mech room 410 fire caulk line set ceiling mech room 412 entry door won't latch 3rd floor not ready 300 deadbolt deck door won't throw 301 ok 302 deadbolt deck door won't fully extend 303 provide deadbolt bed deck door, GFCI above toilet hot neutral reverse
---	--------------------------	--

304 missing deck rail

Room next to elevator open j box, door casing

305 ok

I had Occupancy Inspection at 13:30 3rd,2nd,1st, floor & garages not inspected .

**Comments:**