

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202580
Address: 1316 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Wednesday, November 25, 2020

Corrective Action Required:

1	Misc	-Erosion control requires continuous maintenance. Repair damaged sections within 2 business days -street cleanup required -maintain gravel filter No further inspections until complete
---	------	--

Comments: