

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193184
Address: 1409 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Not Ready	Wednesday, November 25, 2020

Corrective Action Required:

1	Misc	-Seal all penetrations in siding, seal along top of meter can and AC disconnect -Sump pump discharge minimum 36" from foundation -Remove paint covers from all smokes - basement -GFCI protection required at washing machine receptacle -Access required to jacuzzi tub motor master bath
---	------	--

INTERIOR ITEMS INCOMPLETE AT INSPECTION- RECALL WHEN READY

Comments: