

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193519
Address: 1504 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Wednesday, November 25, 2020

Corrective Action Required:

1	Misc	- INSTALL HOOD AND RANGE, HOOD HAD OPEN WIRING AT WALL. -INSPECT ALL EXTERIOR ITEMS A RE-INSPECTION.
---	------	---

Comments: