

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201699
Address: 1618 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, November 25, 2020

Corrective Action Required:

1	Misc	- Seal fireplace Fireblock lid -Complete gas line install at fireplace -Fireblock at NE living room wall -seal penetrations through air return in basement ceiling, NE side -terminate NM at basement bath ceiling -Fireblock bathroom NE wall at top -Over bored floor joist above electric service panel, multiple holes bored within 2"
---	------	--

Comments: