

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203821
Address: 1541 SW MANOR LAKE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Patrick Schonfeldt	Failed	Wednesday, November 25, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Sheetrock inspection required for rated firewall assembly- Charred pex water line above master bedroom and master bath wall- BOCCA protection plates at top and bottom plates for DWV, pex- Secure all DWV 2" or less at mid point (vertical runs)- Damaged wiring at HVAC hall bath ceiling |
|---|------|--|

Comments: