

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Wednesday, November 25, 2020

Corrective Action Required:

1	Misc	- INSULATED WITHOUT APPROVAL REMOVE INSULATION FOR INSPECTION - - PROVIDE 3RD PARTY INSPECTION REPORTS - - DO NOT COVER WORK WITHOUT APPROVAL -
---	------	---

Corrective Action Required:

3	Misc	- PROVIDE SPECIAL INSPECTIONS REPORTS FROM TERRACON - - COVER FACED INSULATION ABOVE CEILING - - PROVIDE BACKING FOR ROOFTOP ACCESS LADDER - - ROOF DRAIN ROOM # 119 - - OK to Sheetrock west wall & one side interior walls -
---	------	--

Comments: