

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193184
Address: 1409 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, November 30, 2020

Corrective Action Required:

1	Misc	-LOCATE ELECTRICAL RECEPTACLE FOR JACUZZI TUB PUMP MOTOR IN MASTER BATH, TEST OF GFCI REQUIRED
INTERIOR ITEMS INCOMPLETE AT INSPECTION- RECALL WHEN READY		

Comments: