

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192214
Address: 3332 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, November 30, 2020

Corrective Action Required:

1	Misc	-Cover plate at basement bar receptacle -Label all dedicated receptacles in garage and unfinished basement as not GFCI protected -Sump pump discharge minimum 36" from foundation -Joist hager angel clip at dbl joist connection to ledger -Max overcurrent protection for AC compressor 35 amps
---	------	---

Comments: