

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202233
Address: 470 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Mechanical Inspection - Commercial	Michael Harkins	Partial	Tuesday, December 01, 2020

Corrective Action Required:

1	Misc	Underslab for pedicure/manicure station exhaust approved
---	------	--

Comments: