

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200946
Address: 1631 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, December 01, 2020

Corrective Action Required:

1	Misc	-Resolve outstanding inspection fee(s) -Install deadbolt front door -Seal around exterior light fixtures -Gutters and downspouts required -Splash blocks at all downspout locations, minimum 36" distance from foundation -Obtain lawn irrigation system permit -Bolt outer ply of rim to ledger at deck and add angel clip to inner ply -Provide (2) bolts per post/rim connection at deck
---	------	--

Comments: