

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192860
Address: 1901 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, December 01, 2020

Corrective Action Required:

1	Misc	- ALL ROUGH FAILED 3/3/20 PROVIDE CITY APPROVED PLANS TO VERIFY LVLs UNDER KITCHEN ISLAND & PROTECT WIRING UNDER SERVICE PANEL COVERED - - SEAL TOP OF METER CAN & EXTERIOR PENETRATIONS - - UNABLE TO LOCATE TEMPERED GLASS MARK ON ACTIVE SHOWER DOOR MASTER - - PROVIDE FLOOD LIGHT FOR REAR EXTERIOR LIGHTING MIN ONE 100 WATT - - DECK POST MUST BE CENTERED ON OR IN FOOTING (PIER) R507.3 -
---	------	--

Comments: