

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200261
Address: 340 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, December 02, 2020

Corrective Action Required:

1	Misc	- PROVIDE MIRROR RESTROOM 40" TO REFLECTIVE SURFACE - - INSULATE PIPES UNDER VANITY IN RESTROOM - - PROVIDE ADDRESS REAR DOOR - - PROVIDE ADDRESS METER CAN /DISCONNECT - - MOUNT FIRE EXTINGUISHER -
---	------	---

Comments: