

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202580
Address: 1316 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	John Morris	Failed	Wednesday, December 02, 2020

Corrective Action Required:

1	Misc	-Provide pipe sleeve 2 sizes greater than the pipe penetrating the foundation wall
		-Ok to backfill except for area at foundation. Excavated area to be left open should be fenced off. Schedule re-inspection

Comments: