

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Commercial Curb Inspection	John DiMauro	Partial	Thursday, October 22, 2020

Informational:

1 Misc

On Friday, 10-23-2020. R&R Concrete is pouring CG-1 curbing up along the interior of the building. All forms and sub-grade met spec's to pour concrete. Contractor is told they needed to get and use thermal blankets. Anticipated temp. For the low is 30 degrees.

Comments: