

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192517

Address: 2700 NE MCBAINE DR, Unit:IR, LEES SUMMIT, MO 64064
2700 NE MCBAINE DR, LEES SUMMIT, MO
64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------|--------------|----------|--------------------------------|
| DE - Storm - Pipe | John Jackson | Passed | Tuesday, September 22, 2020 |

Informational:

1 Misc

Contractor began to install storm line #1 starting at existing junction box. (Sta 0+00 to 1+18.64) Approximately 118' feet of 24" HDPE was installed. STD 30" Nyoplast Curb Inlet was installed @ Sta 0+13.32 on Line #1.

Comments: