CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20192517 Address: 2700 NE MCBAINE DR, Unit:IR, LEES SUMMIT, MO 640642700 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspectio | on: | Inspector: | Outcome: | Date: |
|----------------|----------------|--|----------|--------------------------------|
| DE - Stor | m - Pipe | John Jackson | Passed | Tuesday, September 22, 2020 |
| Informational: | | | | |
| 1 Informat | Misc ional: | Contractor began to install storm line 1 starting at existing junction box. | | |
| 2 | Misc | Contractor installed approximately 70 feet of 24"HDPE & 20 feet of 18" HDPE on 5/7/20. On 5/6/20 approximately 118 feet of 24" HDPE. 3/30" Nyoplast curb inlet was installed at Sta. 0+13.32, 1+19.64, & 1+63.49 on storm line #1. | | |
| Informational: | | | | |
| 3 | Misc | Contractor installed approximately 25' of 12"HDPE on Storm line #3. Contractor is installing approximately 79' of 12" HDPE & 62' of 8" HDPE Storm line #4. | | |

Comments: