

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192517

Address: 2700 NE MCBAINE DR, Unit:IR, LEES SUMMIT, MO 64064
2700 NE MCBAINE DR, LEES SUMMIT, MO
64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Hydrant Inspection	John Jackson	Passed	Tuesday, September 22, 2020

Informational:

1 Misc

Hydrant was installed on existing 8" water main near 2641 NE Mc Baine Dr as per project plans. 8" sleeve and 8"x6" tee was installed on existing water main. Water was main was flushed and restored to normal operation. Hydrant will need an extension to bring it to final grade.

Comments: