

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192517

Address: 2700 NE MCBAINE DR, Unit:IR, LEES SUMMIT, MO 64064
2700 NE MCBAINE DR, LEES SUMMIT, MO
64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line Construction Inspection	John Jackson	Passed	Tuesday, September 22, 2020

Informational:

1 Misc

Contractor (Kat Construction) installed an 8" sleeve & 8"X8" tee tie in for the fire line and a 8" valve. All fittings and pipes up to 8" valve were swab with chlorine. All ductile fittings were wrapped in plastic. Contractor poured backing block. Line was flushed placed back in service.

Comments: