

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200905
Address: 2521 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Friday, December 04, 2020

Corrective Action Required:

1	Misc	-Erosion control requires continuous maintenance. Reestablish methods within two business days -Immediate Street clean up required -No further inspections until complete
---	------	---

Comments: