

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082159 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------------|----------|---------------------------|
| Occupancy Inspection - Codes Commercial | Patrick Schonfeldt | Failed | Friday, December 04, 2020 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | - INSTALL CORRECT PANEL COVERS ON PANELS IN ROOF ACCESS ROOM. - INSTALL CORRECT CONDUIT IN ROOF ACCESS ROOM. -COMPLETE PARKING LOT LIGHT POLES, INSPECT ELECTRICAL AT RE-INSPECTION. - SOD, FINAL GRADE -- AS PER A101 UL DESIGN U419 2 LAYERS IS REQUIRED ON BOTH SIDES OF WALL TO CLOSE THIS PERMIT. INCLUDING THE LABELING OF THE WALL. |
|---|------|--|

Comments: