

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201531
Address: 4399 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|---------------------------|
| Gas Service Inspection - Residential | Patrick Schonfeldt | Failed | Friday, December 04, 2020 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | - SECURE GAS FLEX LINE AT FIREPLACE - GAS PRESSURE GAUGE AT 0, MUST MAINTAIN 10 PSI FOR 15 MINUTES |
|---|------|---|

Comments: