

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200811

Address: 3521 SW MARKET ST, Unit:IR, LEES SUMMIT, MO 64082
3521 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Patrick Schonfeldt	Failed	Friday, December 04, 2020

Corrective Action Required:

1 Miscellaneous
Correction

AREAS APPROVED:

-CONDUIT FOR SECONDARY POWER FROM TRANSFORMER ON NORTH
CORNER OF LOT TO SOUTHEAST CORNER OF BUILDING
-CONDUIT FROM SOUTHEAST CORNER OF BUILDING TO SOUTHWEST CORNER
OF BUILDING FOR MONUMENT SIGN, VAULT, AND FIRE BOX AND EAST FOR
FUTURE USE AND SITE LIGHTING LOOP
-CONDUIT AT SOUTHEAST CORNER OF LOT FOR LIGHT POLE AND FUTURE USE

Corrective Action Required:

2 Misc

- 12/4 - UNDERGROUND ELECTRICAL TRENCH DUG BUT NO CODUIT IN TRENCH,
RESCHEDULE WHEN CONDUIT COMPLETE

Comments: