

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172538
Address: 241 NW KESSLER DR, Unit:G, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Morris	Failed	Monday, December 07, 2020

Corrective Action Required:

1	Misc	-replace damaged stud from electrical installation behind exterior panel -provide grounding electrode at sub panel per 250.32(A)
---	------	---

Comments: