

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192860  
Address: 1901 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Monday, December 07, 2020

Corrective Action Required:

1	Misc	- TJI FLOOR PLAN CALLS FOR LVLs UNDER KITCHEN ISLAND. HAVE ENGINEER OK THE SINGLE TJI JOISTS UNDER KITCHEN ISLAND OR INSTALL PER PLAN - SEAL TOP OF METER CAN & EXTERIOR PENETRATIONS - - UNABLE TO LOCATE TEMPERED GLASS MARK ON ACTIVE SHOWER DOOR MASTER **THE MARKING MUST INDICATE THE APPROVED SAFETY GLAZING STANDARD (CPSC 16 CFR 1201 TYPE II OR ANZI Z97.1 A
---	------	---

**Comments:**