

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200845

Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Monday, December 07, 2020

Corrective Action Required:

1 THE FOLLOWING
AREAS ARE
APPROVED

THE FOLLOWING AREAS ARE APPROVED TO COVER:

ROOMS-, 49,60,61
ROOM 77A,77B-
ROOMS 110A,111A,112A,113A,114A,115A,116A,117A,118A;
PATIENT ROOMS 110-118, 81,83,85,87,89,91,93,95,96,98,100,102,1043,106
HARD LIDS UNIT BATHROOMS-081A, 083A, 085A, 087A, 089A, 091A, 093A,
095A, 096A, 098A, 100A, 102A, 104A, 106A,
WORK STATION 1B099,1B135, 1B119
HARD LIDS AT: NOURISH 1B133, STRETCHER/ EQUIPT STORAGE 1B120
NURSE'S STATION 1B088 SOFFITS

EMERGENCY:
TOILETS 1B001, 1B002
TRIAGE 1B003, 1B004
CORRIDOR B102 TO LINE B2.3
WAITING 1B00C TO LINE B2.3

Comments:

