

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Michael Harkins	Failed	Monday, December 07, 2020

Corrective Action Required:

1	Misc	- RECALL WHEN PIERS/LIGHT POLE BASES DUG, REBAR & GROUND ROD IN PLACE, ALSO CALL FOR UNDERGROUND ELECTRICAL FOR INSPECTION BEFORE COVERING -
---	------	--

Comments: