

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203857
Address: 2358 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Tuesday, December 08, 2020

Corrective Action Required:

1	Misc	-Erosion control requires continuous maintenance. Repair damaged sections at curb line and establish methods at rear property line within two business days -street cleanup required
---	------	---

Comments: