

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20200811

Address: 3521 SW MARKET ST, Unit:IR, LEES SUMMIT, MO 64082  
3521 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Patrick Schonfeldt	Partial	Tuesday, December 08, 2020

Corrective Action Required:

1      Miscellaneous  
Correction

AREAS APPROVED:

- CONDUIT FOR SECONDARY POWER FROM TRANSFORMER ON NORTH CORNER OF LOT TO SOUTHEAST CORNER OF BUILDING
- CONDUIT FROM SOUTHEAST CORNER OF BUILDING TO SOUTHWEST CORNER OF BUILDING FOR MONUMENT SIGN, VAULT, AND FIRE BOX AND EAST FOR FUTURE USE AND SITE LIGHTING LOOP
- CONDUIT AT SOUTHEAST CORNER OF LOT FOR LIGHT POLE AND FUTURE USE
- 12/7 - CODUIT AT EAST SIDE BEHIND BUILDING SOUTH HEADING WEST AT PARKING LOT CORNER ABOUT 40' PAST CORNER OF LOT
- 12/8 - CODUIT AT SOUTH SIDE OF LOT RUNNING WEST FOR MONUMENT SIGN ALONG WEST SIDE OF LOT ENDING AT MAIN PARKING LOT ENTRANCE FOR LIGHT POLE BASES

**Comments:**