

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193536
Address: 1410 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Patrick Schonfeldt	Failed	Wednesday, December 09, 2020

Corrective Action Required:

1	Misc	Uncover manhole MH U-2 as shown on plot plan
---	------	--

Comments: