

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202110
Address: 2931 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, December 09, 2020

Corrective Action Required:

1	Misc	-Fireblock penetrations in wood fire blocking made by other trades -Fireblock top plate penetrations in basement -Terminate lighting outlet in basement bedroom
---	------	---

Comments: