

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201354
Address: 2918 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Wednesday, December 09, 2020

Corrective Action Required:

1	Misc	- No deck pier inspection performed - submit engineer report - Nail off joist hangers at deck
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	No Deck pier inspection on record Sod splash blocks Repair drywall light switch garage near self closing door Nail joist hanger deck Sump pump discharge 36" from foundation Secure whip at A/C condenser Plans call for full height Continuous 6x6 cedar post at covered deck
---	-----------------------------	--

Comments: