CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201648

Address: 161 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes John Morris Failed Wednesday,

Residential December 09, 2020

Corrective Action Required:

1 Misc -provide as graded plot plan for review

- -Final grade and sod per approved as graded plot plan, ensure public utility valve boxes are accessible at grade
- -Repair damage sections of erosion control
- -Remove debris from sidewalk, Street, curb/gutter and storm inlet boxes
- -Sump piping to discharge minimum 36" from foundation
- -Seal all exterior penetrations
- -Provide ladders at basement egress window wells
- -Remove trash and construction debris
- -Remove paint covers from smoke/carbon monoxide alarms
- -Complete cooktop installation
- -Remove paper from batt insulation in unfinished basement area
- -Branch circuits that supply 120-volt, single-phase, 15 and 20 amp circuits installed in kitchens, family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sun-rooms, recreations rooms, closets, hallways, laundry areas and similar rooms or areas require AFCI protection
- -provide building address on the front side of structure, fronting the street

the property is addressed to.

Comments:	
------------------	--