

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200368
Address: 1614 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Deck Final Inspection - Residential	Michael Harkins	Failed	Wednesday, December 09, 2020

Corrective Action Required:

1	Misc	-JOIST HANGERS MISSING NAILS -4' SPHERE SHALL NOT PASS THROUGH RAILING -POST TO BEAM CONNECTION PER CODE
---	------	--

Comments: