

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200757
Address: 2517 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	John DiMauro	Failed	Wednesday, December 09, 2020

Informational:
1 Misc

PRE POUR INSPECTION

The forms are set and there appears to be sufficient compacted aggregate.

Informational:
2 Misc

The north section of the sidewalk is poured and in compliance.

Informational:
3 Misc

PRE POUR INSPECTION

The south sidewalk section is formed and there appears to be sufficient compacted aggregate.

Corrective Action Required:
4 Misc

POST POUR INSPECTION FAILED.

The cross slope of the sidewalk is in compliance however there are two cracked sidewalk panels that need correction before acceptance.

Comments: