

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201862  
Address: 1812 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Patrick Schonfeldt	Failed	Thursday, December 10, 2020

Corrective Action Required:

1	Misc	- COMPLETE GAS LINE INSTALL AT FIREPLACE - PRESSURE TEST AFTER FIREPLACE GAS LINE INSTALL COMPLETE
---	------	---

**Comments:**