

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200799
Address: 4402 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, December 10, 2020

Corrective Action Required:

1	Misc	-UNCOVER MANHOLE AT FRONT OF LOT AS SHOWN ON PLOT PLAN - RAISE MANHOLE TO GRADE
---	------	---

TCO EXPIRATION EXTENDED TO 12/11/20

Comments: