

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201500
Address: 2922 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Deck Final Inspection - Residential	Patrick Schonfeldt	Failed	Friday, December 11, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE (2) BOLTS PER RIM/ POST CONNECTION -SUPPORT END JOIST AT HOUSE AT SOUTHEAST CORNER OF DECK
---	--------------------------	--

Comments: