## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20201500

Address: 2922 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Friday, December 11,

Residential 2020

Corrective Action Required:

1 Miscellaneous

Correction

Corrective Action Required:

2 Miscellaneous -FINAL GRADE AND SOD

Correction -SPLASH BLOCKS AND SUMP DRAINAGE

-OPEN ELECTRICAL BOX IN CEILING OF FAMILY ROOM
-PROVIDE HIGH/LOW VENTILATION FOR COMBUSTION AIR

-PROVIDE (2) BOLTS PER RIM/ POST CONNECTION

-SUPPORT END JOIST AT HOUSE AT SOUTHEAST CORNER OF DECK

-SEAL PENETRATION AT INTERSYSTEM BONDING BAR

Comments: