

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Passed	Friday, December 11, 2020

Informational:
1 Misc Forms were placed and aggregate was present and compacted. They poured over 6 inches of KCM MB mix. RP 12-7-20

Informational:
2 Misc Finished sidewalk meets LS and ADA specs. RP 12-11-20

Comments: