

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20203605

Address: 500 NW OLIVE ST, LEES SUMMIT, MO 64063412 NW OLIVE ST, LEES SUMMIT, MO 64063408 NW  
OLIVE ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Hydrostatic Test</b>	Joe Starlin	Passed	Wednesday, December 16, 2020

Informational:

1 Misc 12-16-20 1:10pm Howerton Plumbing are working on getting the hydrostatic test set up.

Informational:

2 Misc 12-16-20 1:10pm Howerton Plumbing are working on getting the hydrostatic test set up. We started the test at 1:30pm it has been two hours and it has held at 150 psi. This is a pass.

**Comments:**