



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20200445	Date:	December 17, 2020
Project Title:	MID-CONTINENT PUBLIC LIBRARY - COLBERN ROAD	Applicant:	
Location:	1000 NE COLBERN RD, LEES SUMMIT, MO 64064		PROGRESSIVE ELECTRONICS INC 6102 ARLINGTON AVE RAYTOWN, MO 64133
Type of Work:			
Occupancy Group:	A-3		
Description:	NEW LIBRARY	Primary:	(816) 765-5750
Construction Type:	Type IIB (Unprotected)		
Map Page:	175V		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.