

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202029
Address: 1245 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Thursday, December 17, 2020

Corrective Action Required:

1	Misc	-CONNECT THE DRAIN TILES TO THE SUMP PIT
---	------	--

****NEXT TIME, PLEASE BACKFILL TO FOUNDATION WALL FOR FULL VISUAL ACCESS**

Comments: