

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203968
Address: 1308 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Morris	Failed	Thursday, December 17, 2020

Corrective Action Required:

1	Misc	-provide outdoor air for mechanical equipment -provide updated panel schedule -ensure all junction boxes have covers -lighting fixture prohibited to be supported by electrical conduit -properly secure GFCI receptacle in restroom -receptacle outlet behind counter to be flush with finished surface -plug all unused holes in outlet boxes -cap future plumbing fixture stub -Tamperproof caps at condensing units
---	------	---

Comments: