

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201396
Address: 1812 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, December 17, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Submit as graded plot plan for review-Complete final grade and sod-Post permanent complete address-Gutters and downspouts required-Place splash blocks at all downspout and sump pump discharge locations, minimum 36" distance from foundation-Seal all penetrations in siding, seal along top of AC disconnect and meter can-Seal around exterior light fixtures-Complete stone/siding at exterior garage, front porch-security screws, provide (2) 3" screws each exterior hinge and strike plate - patio door-Cover plates at all switches and outlets-size attic access to fit and seal properly 2nd floor laundry, Sheetrock broken
---	------	--

Comments: